



REFERENCE NUMBER: SPAPC.ERDF 004/2018

Restoration of St Paul's Anglican Pro-Cathedral

RE-ISSUE

TENDER FOR THE RESTORATION OF THE EXTERNAL & INTERNAL FABRIC OF THE TOWER & SPIRE, & OTHER INVESTIGATIVE AND ANCILLARY WORKS

CLARIFICATION NOTE 1

Date: 29/05/2019

Clarifications:

1. Clarification sought:

What is the number of electrodes needed since Drawings ICCP 001, and 002 show that x2 No. Ag/AgCl KCl and x2 No. Pseudo electrodes are to be installed, but BoQ Item D, D1.2.6 states that x120 No. are to be priced.

Clarification reply:

There are four (similar) zones and each zone requires 2 Ag/AgCl reference electrodes and also 2 Pseudo reference electrodes. A total of 16 reference electrodes in total. Item D1.2.6. should be 16 No. and item D.1.2.5 should be 1.00 sum.

2. Clarification sought:

There are x2 No. local rectifier units (LRUs) each comprising three (3) d.c. outputs rated at 1A/12V d.c. are specified, however the drawings only show 4 zones, but the LRU's make 6 zones, what shall we price for since it is unclear?

Clarification reply:

The specification is for 4 zones and the CP design is based on typical equipment (which have 3 zones for a local rectifier unit). So for 2 LRUs, two zones would be unused (or possibly used as spares for any other CP applications within the tower).

All other tender documents, conditions and requirements, which are not superseded by this clarification, remain in place.

Reminders:

1. Bidders are reminded that the deadline for submission is 17thJune 2019 at 10:30am.

Clarifications are uploaded on <u>www.savethecathedral.com</u> Link to specific tenders' page: <u>http://www.savethecathedral.com/erdf/</u>



Operational Programme I – European Structural and Investment Funds 2014-2020 "Fostering a competitive and sustainable economy to meet our challenges" Project ispart-financed by the European Regional Development Fund Co-financing rate: 80% European Union; 20% St Paul's Anglican Pro-Cathedral Funds

